

# TEST CERTIFICATE

## Determination of the anti-slip property of floor coverings in workrooms and fields of activities with slip danger

Tested material: **plastic material**

Kind of material: self-adhesive plastic film made of vinyl  
Article description: EcoFloor R9 - 90 mic Matt Floor Laminate with Anti-Slip Surface  
Item number: E666  
Dimensions: as specified: 1,05/1,37/1,52 x 50 [m];  
test specimens: 1000 x 500 x 0,1 [mm]  
colour: transparent, matt  
Surface: flat, fine-rough  
Producer/supplier: GENERAL FORMULATIONS  
309 S. UNION, SPARTA  
49345 Michigan / USA

Client: GF General Formulations GmbH  
Hansestraße 105  
51149 Köln

Certificate No.: 90102001.001e

Test date: 24.03.2020

Sampling: Sent by the customer to the research institute


Test method: **DIN 51130** (edition 02/2014)  
"Testing of floor coverings - Determination of the anti-slip property -  
Workrooms and fields of activities with slip danger - Walking method - Ramp test"  
Delivery of the test material has been effected in ready-to test surface condition.

Test result: Average total acceptance angle: **7,3°**

Assessment: **Classification group of anti-slip property: R9**

**SÄUREFLIESNER-VEREINIGUNG E. V.**  
Institut für Wand- und Bodenbeläge  
Managing Director

  
Dipl.-Ing. Friedrich Höltekemeyer



Großburgwedel, 14.05.2020  
Schu/Ke

This test certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test specimen. The certificate is given for 5 years (starting from test date). Publication and reproduction of this certificate is only allowed in unabridged form.



- Institut für Wand- und Bodenbeläge -  
**SÄUREFLIESNER-VEREINIGUNG E.V.**

Im Langen Felde 4, 30938 Burgwedel · Telefon (0 51 39) 99 82-0 · Telefax (0 51 39) 99 82-40 · E-Mail: info@saeurefliesner.de  
Nach DIN EN ISO/IEC 17025 durch die DAKKS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00  
aufgeführten Bereiche. Vom DIBT nach LBO unter der Kenn-Nr. NDS 20 anerkannte und nach EU-BauPVO notifizierte Stelle NB 1212.

